






1					CABLE GLAND	PG25 SEALING RANGE 13-21mm				2			
number	label				The name of the		specifications				quantity	note	
The contract no						Cabinet No						Factory number	
						BBWX-1(VOLTACON,AC230V) AC COMBINER BOX							
tag	Change the file no		The signature		date			Pattern marker				The proportion	
design			standardized			Arrangement diagram							
drawing			Review and approval										
check			approval										
process			date					VOLTACON[®] ENERGY SYSTEMS					



4	CT	Mutual Inductor	ESCT-T24-100/5	1	
3	KWH	Meter	SDM120CT-M AC230V	1	
2	QF	AC MCB	NXB-63/2P C32A	1	
1	SPD	AC SPD	BUA-40KA/2P AC275V	1	
number	label	The name of the		specifications	quantity
The contract no		Tank no		Factory number	
				BBWX-1(VOLTACON,AC230V) AC COMBINER BOX	
tag	Change the file no	The signature	The date of	Pattern marker	The proportion
design		standardized		VOLTACON[®] ENERGY SYSTEMS	
drawing		Review and approval			
check		approval			
process		The date of			